

(1) EC-TYPE EXAMINATION CERTIFICATE

(2) Equipment or protective system intended for use in potentially explosive atmospheres - Directive 94/9/EC

(3) EC-Type Examination Certificate Number: **KEMA 04ATEX2128**

(4) Equipment or protective system: **Flow Switch Model V6 and Float Switch Model L6**

(5) Manufacturer: **Dwyer Instruments, Inc.**

(6) Address: **102 Indiana Highway, Michigan City, Indiana 46360, USA**

(7) This equipment or protective system and any acceptable variation thereto is specified in the schedule to this certificate and the documents therein referred to.

(8) KEMA Quality B.V., notified body number 0344 in accordance with Article 9 of the Council Directive 94/9/EC of 23 March 1994, certifies that this equipment or protective system has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of equipment and protective systems intended for use in potentially explosive atmospheres given in Annex II to the directive.

The examination and test results are recorded in confidential report no. 2073611.

(9) Compliance with the Essential Health and Safety Requirements has been assured by compliance with:

EN 50014 : 1997

EN 50018 : 2000

(10) If the sign "X" is placed after the certificate number, it indicates that the equipment or protective system is subject to special conditions for safe use specified in the schedule to this certificate.


(11) This EC-Type Examination Certificate relates only to the design, examination and tests of the specified equipment or protective system according to the Directive 94/9/EC. Further requirements of the directive apply to the manufacturing process and supply of this equipment or protective system. These are not covered by this certificate.

(12) The marking of the equipment or protective system shall include the following:



II 2 G EEx d IIC T6 ... T4 or 115 °C

Arnhem, 19 May 2004
KEMA Quality B.V.



T. Pijpker
Certification Manager

© This Certificate may only be reproduced in its entirety and without any change

(13)

SCHEDULE

(14)

to EC-Type Examination Certificate KEMA 04ATEX2128

(15) **Description**

The Flow Switch Model V6 is used to indicate if a media is flowing in conduit. Float Switch L6 is used to indicate if a fluid media is above or below a particular level in a tank or reservoir.

Ambient temperature range: -20 °C ... +75 °C

The relation between temperature class and medium temperature is shown in the table below:

Temperature class	Max. medium temperature
T6	75 °C
T5	90 °C
T4 or 115 °C	105 °C

Electrical data

Voltage max. 250 V ac or 30 V dc
 Current max. 5A ac or 3 A dc inductive / 5 A dc resistive

Installation instructions

Cable connection

The cable entry device shall be certified in type of explosion protection flameproof enclosure "d", suitable for the conditions of use and correctly installed.

For ambient temperatures over 70 °C, cables and cable glands suitable for at least 90 °C shall be used.

Conduit connection

An EEx d certified sealing device such as a conduit seal with setting compound shall be provided immediately to the entrance of the valve housing.

For ambient temperatures over 70 °C, the wiring and setting compound in the conduit seal shall be suitable for at least 90 °C.

Routine tests

Each flow switch and float switch shall be submitted to a routine test according to Clause 16 of EN 50018 using a test pressure of 12 bar for at least 10 seconds.

(16) **Report**

KEMA No. 2073611.

(17) **Special conditions for safe use**

None.

(18) **Essential Health and Safety Requirements**

Covered by the standards listed at (9).

SCHEDULE

(13)

(14)

to EC-Type Examination Certificate KEMA 04ATEX2128

(19) **Test documentation**

1. Certificate of Conformity INIEX 91C.103.956

dated

2. Description (6 pages)

08.04.2004

3. Drawing No. 82-000887-43

05.02.2004

82-000887-44

08.04.2004

82-000887-45

08.04.2004

82-000887-46

08.04.2004

82-000887-47

08.04.2004

82-000887-48

08.04.2004

82-000900-00, rev. 3

23.01.2003

82-000900-01, rev. 2

24.06.2003