
Pressure**636-a-LP****636-a-LP. Electronic Pressure Transmitter.**

XP / I / 1 / BCD / T6 Ta = 60°C; DIP / II,III / 1 / EFG / T6 Ta = 60°C; Type 4
a = Pressure range 0, 1, 2, 3, 4 or 5.

Company Name:	Dwyer Instruments Inc
Company Address:	Box 373, Michigan City, Indiana 46360, USA
Company Website:	http://www.dwyer-inst.com
New/Updated Product Listing:	No
Listing Country:	United States of America
Certification Type:	FM Approved
Hazardous Location Classification:	XP / I / 1 / BCD / T6 Ta = 60°C, DIP / II,III / 1 / EFG / T6 Ta = 60°C; Type 4